Wendy Henderson
Director of Public Health

MEMORANDUM

DATE: 13 February 1997

TO: ALL CONCERNED

FROM: Wendy Henderson

RE: Designing for whirlpool capacity

☪☪☪☪☪☪☪☪☪☪☪☪☪☪☪☪☪☪☪☪☪☪☪☪☪☪☪☪☪☪☪☪☪☪☪☪☪

The Board of Health, at its meeting of 22 January 1997 adopted the following policy in regards to DESIGNING FOR WHIRLPOOL CAPACITY

volume of whirlpool
\- 45 gal.
= additional wastewater x # bedrooms / 2 = additional design capacity required

Or in other words ; high volume appliances such as whirlpools shall be accommodated by a design provision of : the volume of the high volume tub, in excess of 45 gallons, times one half the number of bedrooms.

02/13/97 10:07:25 AM